



North Carolina Department of Environment and Natural Resources

Pat McCrory
Governor

John E. Skvarla, III
Secretary

June 25, 2015

CERTIFIED MAIL
RETURN RECEIPT REQUESTED
7012 2210 0002 4887 1526

Mr. Edward Waltz, Mayor
Town of Maysville
P.O. Box 265
Maysville, North Carolina 28555

Subject: **NOTICE OF VIOLATION**
NOV-2015- MV-0085
Permit No. NC0021482
Town of Maysville WWTP
Jones County

Dear Mayor Waltz:

A review of Maysville's monitoring report from March 2015 to August 2014 showed the following violations:

Parameter	Date	Measuring Frequency	Violation
Total Mercury (as Hg) - Concentration	March 2015	Quarterly	Frequency Violation
Total Mercury (as Hg) - Concentration	December 2014	Quarterly	Frequency Violation
pH	November 2014	Weekly	Frequency Violation
pH	November 2014	Weekly	Frequency Violation
pH	November 2014	Weekly	Frequency Violation
pH	November 2014	Weekly	Frequency Violation
pH	October 2014	Weekly	Frequency Violation
pH	October 2014	Weekly	Frequency Violation
pH	September 2014	Weekly	Frequency Violation
pH	September 2014	Weekly	Frequency Violation
pH	August 2014	Weekly	Frequency Violation
pH	August 2014	Weekly	Frequency Violation
pH	August 2014	Weekly	Frequency Violation

Division of Water Resources – Water Quality Regional Operations Section – Washington Regional Office
943 Washington Square Mall, Washington, NC 27889
Phone: 252-946-6481 \ Fax: 252-975-3716 \ Internet: www.ncdenr.gov

Parameter	Date	Limit Value	Reported Value	Limit Type
Average Flow Exceeded	February 2015	0.180 mgd	0.203 mgd	Monthly Average Exceeded
Fecal Coliform	February 2015	400/100ml	9,500/100ml	Weekly Geometric Mean Exceeded
Fecal Coliform	February 2015	400/100ml	500/100ml	Weekly Geometric Mean Exceeded
Average Flow Exceeded	January 2015	0.180 mgd	0.212 mgd	Monthly Average Exceeded
Fecal Coliform	January 2015	400/100ml	727/100ml	Monthly Geometric Mean Exceeded
Fecal Coliform	January 2015	400/100ml	1,700/100ml	Weekly Geometric Mean Exceeded
Fecal Coliform	January 2015	400/100ml	6,000/100ml	Weekly Geometric Mean Exceeded
Fecal Coliform	January 2015	400/100ml	415/100ml	Weekly Geometric Mean Exceeded
Average Flow Exceeded	August 2014	0.180 mgd	0.191 mgd	Monthly Average Exceeded
Fecal Coliform	August 2014	400/100ml	773/100ml	Monthly Geometric Mean Exceeded
Fecal Coliform	August 2014	400/100ml	6,000/100ml	Weekly Geometric Mean Exceeded
Fecal Coliform	August 2014	400/100ml	1,800/100ml	Weekly Geometric Mean Exceeded
Fecal Coliform	August 2014	400/100ml	6,500/100ml	Weekly Geometric Mean Exceeded
Fecal Coliform	August 2014	400/100ml	514/100ml	Weekly Geometric Mean Exceeded

Remedial actions should be taken to correct this problem. The Division of Water Resources may pursue enforcement action for this and any additional violations of State law.

To prevent further action, carefully review these violations and deficiencies and respond in writing to this office within 15 days of receipt of this letter. You should address the causes of noncompliance and all actions taken to prevent the recurrence of similar situations. If you should have any questions, please do not hesitate to contact Justin Davis, Environmental Specialist, at 252-948-3942.

Sincerely,

A handwritten signature in cursive script that reads "Robert Tankard".

Robert Tankard
Assistant Regional Supervisor
Division of Water Resources
Water Quality Operations Section

Cc: WQ Central Files
WaRO Enforcement Files